

BALANCING WATER QUALITY AND INFRASTRUCTURE: A CASE STUDY FOR THE BOTTESFORD BECK

Optimizing CSOs, Tanks and Network Performance



SEVERN
TRENT

intertek

Hector Adell Troncho,

Senior Engineer at WSP

Image credit: [<https://www.bottesford.org/bottesford-beck>]

INTRODUCTION

2017


- Background: Catchment Overview and Regulatory Framework
- Creating the right tool
- Options – minimizing construction impact
- Hydraulic Assessment and Challenges
- Water Quality Analysis and Results
- Key Insights and Conclusion

2023

**WFD driver project to protect waterbodies
from deterioration**

BACKGROUND


Catchment overview



- 15.7 km reach
- Catchment area (70.2 km²)
- Population – 85,200
- Upstream Network – 60% Combined, 40% Separate

BACKGROUND

Catchment overview



BACKGROUND

Regulatory Framework

Determinand	90%ile	99%ile	Fundamental Intermittent Standards	Annual Average Concentration
BOD	5 mg/l	11 mg/l		
Un-ionised Ammonia (NH ₃)	0.6 mg/l	1.5 mg/l	Sustainable Cyprinid fishery	
Dissolved Oxygen (DO)			Sustainable Cyprinid fishery	
Phosphate				0.069 mg/l

Looking for a Good or High value for each determinand


Bottesford Beck:

- Type 7 river (lowland high alkalinity)
- Sustainable Cyprinid fishery



BACKGROUND

Historical Water Quality Data



Data from samples taken between 2012 and 2017.

BOD was sampled for 1 year in 2 of the 3 sampling locations.


To determine 99%iles, samples are recommended to be taken regularly



Water Quality Model

CREATING THE RIGHT TOOL

Model parameters





- *BOD Decay rate*
- *Ammonia Decay rate*
- *Nitrification of Ammonia*
- *DO Reaeration rate*
- *Photosynthesis and respiration*
- *Sediment Oxygen Demand*
- *Phosphorus Uptake*

CREATING THE RIGHT TOOL


Model Calibration (2017/2018) – 4 WQ sampling points and gauge stations

Asset type	BOD (mg/l)	NH ₃ (mg/l)	SRP (mg/l)	Temperature (°C)	DO (mg/l)	Source
CSO	90 mg/l	6.3 mg/l	1.05	Variable	Variable	Default
Surface Water	8 mg/l	0.2 mg/l	0.0105 mg/l	Variable	Variable	Default
Yaddlethorpe STW	4.17 mg/l	0.27	1.8	Variable	Variable	Measured





CREATING THE RIGHT TOOL

BOD 99%ile hydrograph post re-calibration



South Grange CSO outfall


CREATING THE RIGHT TOOL



Final Effluent increases SRP

GENERIC OPTIONS

Improvement of SRP – Final Effluent Transfer to the River Trent




Final Effluent Transfer to River Trent



GENERIC OPTIONS

Improvement of UPMs and FIS – Decrease CSO discharges along the Beck



OPTIONS

Minimise construction impact and achieve a good WQ status

Asset	Option 1	Option 2	Option 3	Option 4	Option 5	Option 6	Option 7
Brigg Rd / Station Rd CSO	1,040	850	1,040	1,040	1,040	1,040	1,040
E. C. Lane & E. C Lane 122 CSO	1,495	600	NS	NS	ANMC	NS	ANMC + SWS
Queensway CSO	1,040	850	1,040	NS	ANMC	1,040	ANMC + SWS
Grange Lane North CSO	3,250	2,600	3,250	3,250	3,250	3,250	3,250
South Grange CSO	3,510	2,750	3,510	3,510	3,510	3,510	3,510
Yaddlethorpe STW	3,120	3,120	3,120	3,120	3,120	5,000	3,120


NS – No solution

ANMC – Active Network Management Control

SWS – Surface Water Separation


OPTIONS

Tank interactions with Yaddlethorpe STW worsened BOD results






OPTIONS

Shaft tanks' return flows with the STW tanks are still at max. capacity



OPTIONS – RTC INHIBITION




FINAL RESULTS

% Spill Volumetric reduction in 10 years



Asset	Option 1	Option 3	Option 4	Option 5	Option 6	Option 7
Brigg Rd / Station Rd CSO	73%	73%	73%	73%	73%	73%
E. C. Lane & E. C Lane 122 CSO	55%	0%	0%	20%	0%	33%
Queensway CSO	55%	55%	0%	17%	55%	20%
Grange Lane North CSO	52%	52%	52%	55%	52%	55%
South Grange CSO	54%	54%	54%	54%	54%	54%
Yaddlethorpe STW	33%	33%	33%	33%	45%	31%
Achieves Good Status	Yes	No	No	Yes	Yes	Yes

FINAL PREFERRED OPTION




- BOD 99%ile improves to 'Good' WFD status
- BOD 90%ile remains 'High' WFD status
- NH₃ 99% improves to 'High' WFD status
- SRP improves to 'Moderate' WFD status
- ANMC to mobilise 16,000 m³/year
- 1,000 m³ of SW (1:1 yr) separated (peak of 150 l/s)

ANMC – Active Network Management Control
SW – Surface Water

FINAL PREFERRED OPTION

A mix of shaft tanks, pipes, active network management and separation



KEY INSIGHTS

FE Transfer – Improving SRP	↔	FE Transfer – No dilution for BOD
6x Shaft Tanks – Increased Carbon Footprint	↔	6x Shaft Tanks – Best WQ results
Pump Inhibition System (RTC) – Improves WQ at STW	↔	Pump Inhibition System (RTC) – Higher Retention Times
ANMC – Maximises capacity	↔	ANMC – Little experience
Separation – Delivery constraints	↔	Separation – Sustainable option
CSO spill transfer to Trent – Does not decrease spills	↔	CSO spill transfer to Trent – Best WQ results for the Beck

Finding the right balance





Thank you

wsp.com